



TYPE APPROVAL CERTIFICATE
No. **ELE058611XT/006**

This is to certify that the product below is found to be in compliance with the applicable requirement of the RINA type approval system.

<i>Description</i>	ELECTRIC CABLES
<i>Type</i>	FM2XCY 150/250 V
<i>Applicant</i>	2M KABLO SANAYI VE TICARET A.S. SANCAKTEPE MAHALLESİ, KLAS SOKAK, NO:8, 34580 SILIVRI, ISTANBUL, TURKEY
<i>Manufacturer</i>	2M KABLO SANAYI VE TICARET A.S.
<i>Place of manufacture</i>	SANCAKTEPE MAHALLESİ, KLAS SOKAK, NO:8, 34580 SILIVRI, ISTANBUL, TURKEY
<i>Reference standards</i>	IEC 60092-350; IEC 60092-376.

Issued in **ISTANBUL** on **August 16, 2013**. *This Certificate is valid until* **August 16, 2018**



RINA
Orhan Pekcay

This certificate consists of this page and 1 enclosure

TYPE APPROVAL CERTIFICATE

No. ELE058611XT/006

Enclosure - Page 1 of 1

FM2XCY 150/250 V

Materials/Components

Shipboard instrumentation, control and communication cables, flame retardant, for ships and off-shore units installation.

Rated voltage: 150 / 250 V

Maximum rated conductor temperature: + 85 °C

Type: FM2XCY

Marking: 2MKABLO IEC 60092-376 FM2XCY n x m x s(mm²) 150/250 V IEC 60332-3-22 [METER MARK]

Construction

Conductor: Stranded Electrolytic Annealed Copper Class 2

Insulation: XLPE

Lay-Up: Pairs and quads are stranded in layers

Screen: Electrolytic Copper Wire Braiding

Outer Sheath: PVC (ST2)

Number of Units: 1, 2, 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 19, 20, 24, 37; Cross-sec. area of conductors 0,5 and 0,75 mm²

Reference documents: Technical Specification No: 110-3/2011 (16/03/2012)

Reference Standards: IEC 60092-350; IEC 60092-376; IEC 60332-3-22; IEC 60332-1-2; IEC 60228; IEC 60811; IEC 60754-1; IEC 60754-2; IEC 60092-351; IEC 60092-359

ISTANBUL 16.08.2013

